

RUBY Planned Outage	Start Date	Finish Date	State	Maintenance Activity
X20-537022	6/8/2021	6/8/2021	Nevada	WIELAND FLAT TO NV/OR ST LINE (Segment 50):Desert Valley Compressor Station Annual DOT ESD systems checks. Capacity will be reduced to 1,348 Mdth/d.
X20-544103	6/9/2021	6/9/2021	Nevada	WIELAND FLAT TO NV/OR ST LINE (Segment 50):Desert Valley Compressor Station unit shut down checks. Capacity will be reduced to 1,391 Mdth/d.
X20-556434	6/15/2021	6/15/2021	Nevada	WIELAND FLAT TO NV/OR ST LINE (Segment 50): Wieland Flat Compressor Station Annual DOT ESD systems checks. Capacity will be reduced to 1,335 Mdthd
X20-562091	6/16/2021	6/16/2021	Nevada	WIELAND FLAT TO NV/OR ST LINE (Segment 50): Wieland Flat Compressor Station One unit will be out of service to perform unit shutdown checks. Capacity will be reduced to 1,382 Mdth/d.
X20-562092	6/17/2021	6/17/2021	Nevada	WIELAND FLAT TO NV/OR ST LINE (Segment 50): Wieland Flat Compressor Station One unit will be out of service to perform unit shutdown checks. Capacity will be reduced to 1,382 Mdth/d.
X20-1128397	7/13/2021	7/14/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit electrical inspection. Capacity will be reduced to 1,280 Mdth/d
X20-576899	7/14/2021	7/15/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit electrical inspection. Capacity will be reduced to 1,280 Mdth/d.
X20-587079	7/15/2021	7/16/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit electrical inspection. Capacity will be reduced to 1,280 Mdth/d.
X20-718246	8/3/2021	8/3/2021	Utah	WY/UT STLINE TO UT/NV ST LINE (Segment 30):Wildcat Hills Compressor Station Annual DOT ESD systems checks. Capacity will be reduced to 1,290 Mdth/d.
X20-726383	8/4/2021	8/4/2021	Utah	WY/UT STLINE TO UT/NV ST LINE (Segment 30): Wildcat Hills Compressor Station One unit will be out of service to perform unit shutdown checks. Capacity will be reduced to 1,427 Mdth/d.
X20-726384	8/5/2021	8/5/2021	Utah	WY/UT STLINE TO UT/ NV ST LINE (Segment 30): Wildcat Hills Compressor Station One unit will be out of service to perform unit shutdown checks. Capacity will be reduced to 1,427 Mdth/d.
X20-757111	8/24/2021	8/24/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station Annual DOT ESD systems checks will be performed for 8 hours. Capacity will be reduced to zero.
X20-857413	9/14/2021	9/14/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit shutdown checks and 4000 hour inspections. Capacity will be reduced to 1,337 Mdth/d.

X20-860005	9/15/2021	9/15/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit shutdown checks and 4000 hour inspections. Capacity will be reduced to 1,377 Mdt/d.
X20-872619	9/16/2021	9/16/2021	Wyoming	ROBERSON CREEK - WY/UT ST LINE (Segment 20): Roberson Creek Station One unit will be out of service to perform unit shutdown checks and 4000 hour inspections. Capacity will be reduced to 1,377 Mdt/d.