



Delivering Energy. Improving Lives.

Tennessee Gas Pipeline Company, L.L.C.

System Maintenance, Integrity and Reliability Report

November 17, 2025

Cautionary Statement

- This report contains forward-looking statements. These forward-looking statements are identified as any statement that does not relate strictly to historical or current facts. Forward-looking statements are not guarantees of performance. They involve risks, uncertainties and assumptions. Future actions, conditions or events and future results of operations of Tennessee Gas Pipeline Company, L.L.C. ("TGP") or its parent company, Kinder Morgan, Inc. ("KM"), may differ materially from those expressed in these forward-looking statements. Many of the factors that will determine these results are beyond TGP's or KM's ability to control or predict. These statements are necessarily based upon various assumptions involving judgments with respect to the future and there is no assurance that any of the actions, events or results of the forward-looking statements will occur, or if any of them do, what impact they will have on our results of operations or financial condition. Because of these uncertainties, you are cautioned not to put undue reliance on any forward-looking statement.

- Article X, Section A of TGP's rate settlement in Docket No. RP24-331 ("S&A") requires TGP to prepare an annual report on the operational performance and maintenance activities on its system (the "Report") and host an annual meeting to present and discuss the Report with its customers
- The Report is available as an informational posting on TGP's customer website
- The Report includes the following information:
 - Planned maintenance activities for calendar year 2026;
 - Reconciliation of actual to estimated costs of maintenance activities undertaken in calendar year 2025;
 - Reliability metrics for firm service and compressor availability and outage times for 12-month period ending September 30, 2025

2026 Maintenance Activities

- For calendar year 2026, TGP expects to spend approximately \$301.7mm on maintenance related activities
- Dates and scope of work planned are subject to change

Category/Description	Target Completion Date	Zone 0	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Total Estimated Cost
Pipeline Integrity	2026	\$18,707,874	\$71,041,965	\$15,317,167	\$158,020	\$24,108,850	\$14,386,891	\$7,196,818	\$150,917,584
Pipeline Class Change	2026	\$25,778,379	\$22,673,030	\$0	\$0	\$17,929,017	\$4,750,509	\$0	\$71,130,935
Turbine Exchanges And Compressor Replacement/Overhauls	2026	\$5,713,601	\$16,815,500	\$2,260,932	\$0	\$1,414,826	\$1,470,352	\$275,463	\$27,950,674
Well Bore Integrity	2026	\$0	\$0	\$0	\$0	\$350,000	\$0	\$0	\$350,000
Wells And Gathering	2026	\$0	\$0	\$0	\$0	\$7,770,659	\$0	\$0	\$7,770,659
Air Regulation	2026	\$142,510	\$3,985,552	\$0	\$0	\$0	\$0	\$0	\$4,128,062
Automation	2026	\$0	\$4,056,343	\$0	\$0	\$672,261	\$22,615	\$38,039	\$4,789,258
Measurement-Valves	2026	\$306,516	\$5,531,380	\$577,204	\$0	\$773,236	\$316,165	\$33,250	\$7,537,751
Pipeline - Other	2026	\$3,859,204	\$11,137,067	\$561,850	\$0	\$1,236,208	\$804,402	\$620,024	\$18,218,755
Ancillary Facilities	2026	<u>\$162,134</u>	<u>\$5,783,643</u>	<u>\$798,772</u>	<u>\$0</u>	<u>\$1,061,849</u>	<u>\$857,269</u>	<u>\$229,582</u>	<u>\$8,893,249</u>
TOTAL		\$54,670,218	\$141,024,479	\$19,515,925	\$158,020	\$55,316,906	\$22,608,203	\$8,393,176	\$301,686,927

Cost Reconciliation of 2025 Maintenance Activities

For calendar year 2025, TGP projects to spend approximately \$336.2 mm on maintenance related activities

- Estimate based on year-to-date actuals through end of August plus current forecast for remaining 4 months of the year
- \$30.7 mm higher than initial estimate

Category/Description	Estimated Cost	Actual Cost (8+4)	Variance
Pipeline Integrity	\$159,018,529	\$170,583,662	\$11,565,133
Pipeline Class Change	\$73,224,970	\$72,659,773	(\$565,197)
Turbine Exchanges And Compressor Replacements/Overhauls	\$19,207,557	\$42,583,174	\$23,375,617
Well Bore Integrity	\$350,000	\$350,000	\$0
Wells And Gathering	\$6,029,323	\$6,210,876	\$181,553
Air Regulation	\$10,499,842	\$4,006,316	(\$6,493,526)
Automation	\$4,748,097	\$5,748,843	\$1,000,746
Measurement-Valves	\$6,695,874	\$6,403,779	(\$292,094)
Pipeline - Other	\$16,021,886	\$16,704,909	\$683,023
Ancillary Facilities	\$9,436,453	\$10,697,738	\$1,261,284
ROW	<u>\$185,000</u>	<u>\$252,200</u>	<u>\$67,200</u>
TOTAL	\$305,417,532	\$336,201,270	\$30,783,738

Reliability Metrics: Compressor Availability

Compressor availability for the period October 1, 2024 through September 30, 2025 was approximately 92% (storage and transmission)

Unplanned outages primarily related to equipment failures

		Current Period	Current Period	Current Period	Current Period	Previous Period	y-o-y variance
		Planned Compressor Outage, % of Total Hours 1/	Unplanned Compressor Outage, % of Total Hours 1/	Compressor Outage, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/
Compressor Use	# of Units						
Transmission	513	4.6%	3.4%	8.0%	92.0%	85.4%	6.6%
Storage	4	6.8%	1.1%	7.8%	92.2%	80.1%	12.1%

1/ Compressor availability and outages for each compressor station weighted by horsepower at each station.

Reliability Metrics: Compressor Availability

Major outages for the period October 1, 2024 through September 30, 2025:

					Current Period	Current Period	Current Period	Current Period	Previous Period	y-o-y variance
Compressor Station	Compressor Use	# of Units	Horsepower	Location	Planned Compressor Outage, % of Total Hours 1/	Unplanned Compressor Outage, % of Total Hours 1/	Compressor Outage, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/
260A	Transmission	1	2,100	Southwick, MA	34.7%	2.2%	37.0%	63.0%	30.4%	32.6%
270B	Transmission	1	6,053	Concord, NH	41.1%	0.0%	41.1%	58.9%	100.0%	-41.1%
313A	Transmission	2	4,730	Ellisburg, PA	99.4%	0.0%	99.4%	0.6%	0.2%	0.4%
319	Transmission	1	20,500	Wyalusing, PA	35.8%	0.0%	35.8%	64.2%	100.0%	-35.8%
534	Transmission	7	26,000	Purvis, MS	18.3%	8.9%	27.2%	72.8%	85.8%	-13.0%
542	Transmission	5	29,500	Dekalb, MS	18.3%	2.4%	20.7%	79.3%	51.0%	28.4%
546	Transmission	8	30,000	Columbus, MS	4.8%	20.0%	24.8%	75.2%	68.4%	6.8%
834	Transmission	7	11,350	Winnsboro, LA	19.0%	1.6%	20.6%	79.4%	74.2%	5.3%

1/ Compressor availability and outages for each compressor station weighted by horsepower at each station.

Reliability Metrics: Compressor Availability

Line No.	Compressor Station		# of Units	Horsepower	Location	Current Period	Current Period	Current Period	Current Period	Previous Period	y-o-y variance
						Planned Compressor Outage, % of Total Hours 1/	Unplanned Compressor Outage, % of Total Hours 1/	Compressor Outage, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/
1	1	Transmission	12	17,800	Agua Dulce, TX	0.3%	5.4%	5.7%	94.3%	48.4%	46.0%
2	3A	Transmission	1	10,915	Sinton, TX	0.0%	1.1%	1.1%	98.9%	99.8%	-0.8%
3	9	Transmission	8	22,000	Victoria, TX	0.0%	0.0%	0.0%	100.0%	100.0%	0.0%
4	11A	Transmission	1	20,500	Edna, TX	0.1%	0.1%	0.1%	99.9%	99.6%	0.2%
5	17	Transmission	2	22,700	East Bernard, TX	0.5%	15.3%	15.8%	84.2%	50.0%	34.2%
6	25	Transmission	3	25,600	Cleveland, TX	0.0%	10.6%	10.6%	89.4%	98.7%	-9.3%
7	32	Transmission	20	26,750	Jasper, TX	4.8%	0.2%	4.9%	95.1%	93.8%	1.2%
8	40	Transmission	11	30,400	Natchitoches, LA	5.9%	5.1%	11.0%	89.0%	38.2%	50.8%
9	47	Transmission	11	38,510	West Monroe, LA	5.1%	1.0%	6.2%	93.8%	82.2%	11.6%
10	54	Transmission	16	38,970	Greenville, MS	9.9%	3.9%	13.9%	86.1%	85.4%	0.8%
11	63	Transmission	23	38,150	Batesville, MS	10.5%	8.0%	18.5%	81.5%	79.2%	2.3%
12	71	Transmission	23	34,350	Middleton, TN	0.1%	3.4%	3.5%	96.5%	87.6%	8.8%
13	79	Transmission	3	39,099	Lobelville, TN	0.1%	0.1%	0.1%	99.9%	96.8%	3.1%
14	87	Transmission	22	49,700	Portland, TN	8.4%	2.7%	11.1%	88.9%	91.7%	-2.8%
15	96	Transmission	21	41,200	Campbellsville, KY	0.5%	0.8%	1.3%	98.7%	93.1%	5.7%
16	106	Transmission	18	59,800	Clay City, KY	10.8%	4.5%	15.3%	84.7%	88.5%	-3.8%
17	107A	Transmission	2	4,390	North Means, KY	0.0%	0.0%	0.1%	99.9%	99.7%	0.2%
18	110	Transmission	4	37,100	Morehead, KY	1.0%	0.1%	1.0%	99.0%	88.6%	10.4%
19	114	Transmission	11	44,251	Catlettsburg, KY	1.0%	1.9%	2.9%	97.1%	99.4%	-2.3%
20	118A	Transmission	1	10,771	Tyler Mountain, WV	0.7%	0.0%	0.7%	99.3%	98.1%	1.2%
21	119A	Transmission	1	20,500	Rocky Fork, WV	3.7%	0.0%	3.7%	96.3%	96.3%	0.0%
22	200	Transmission	13	24,200	Greenup, KY	2.4%	0.3%	2.7%	97.3%	97.9%	-0.5%
23	204	Transmission	12	22,970	Albany, OH	3.4%	1.0%	4.5%	95.5%	92.6%	2.9%
24	209	Transmission	13	21,000	Cambridge, OH	4.0%	1.1%	5.1%	94.9%	91.0%	3.9%
25	214	Transmission	13	19,880	Carrollton, OH	2.9%	3.1%	6.0%	94.0%	82.9%	11.1%

1/ Compressor availability and outages for each compressor station weighted by horsepower at each station.

Reliability Metrics: Compressor Availability

						Current Period	Current Period	Current Period	Current Period	Previous Period	y-o-y variance
						Planned Compressor Outage, % of Total	Unplanned Compressor Outage, % of Total	Compressor Outage, % of Total	Compressor Availability, % of	Compressor Availability, % of	Compressor Availability, % of
Line No.	Compressor Station	Compressor Use	# of Units	Horsepower	Location	Hours 1/	Hours 1/	Hours 1/	Total Hours 1/	Total Hours 1/	Total Hours 1/
26	219	Transmission	14	21,550	Mercer, PA	6.2%	2.6%	8.7%	91.3%	83.4%	7.8%
27	224	Transmission	4	8,000	Clymer, NY	0.1%	0.5%	0.6%	99.4%	99.6%	-0.2%
28	229	Transmission	6	8,400	Hamburg, NY	11.3%	0.9%	12.2%	87.8%	96.8%	-9.0%
29	230C	Transmission	4	18,000	Lockport, NY	0.5%	0.1%	0.6%	99.4%	98.9%	0.5%
30	233	Transmission	2	7,000	Geneseo, NY	0.2%	0.5%	0.7%	99.3%	99.9%	-0.6%
31	237A	Transmission	3	8,000	Clifton Springs, NY	4.0%	0.4%	4.4%	95.6%	99.5%	-3.9%
32	241	Transmission	5	18,400	Lafayette, NY	5.9%	2.8%	8.7%	91.3%	93.7%	-2.4%
33	245	Transmission	9	24,419	West Winfield, NY	1.2%	0.1%	1.3%	98.7%	91.0%	7.7%
34	249	Transmission	4	16,200	Carlisle, NY	5.4%	0.2%	5.6%	94.4%	88.8%	5.6%
35	254	Transmission	7	18,710	Nassau, NY	13.2%	0.0%	13.2%	86.8%	98.1%	-11.4%
36	260A	Transmission	1	2,100	Southwick, MA	34.7%	2.2%	37.0%	63.0%	30.4%	32.6%
37	261	Transmission	4	22,717	Agawam, MA	1.2%	0.1%	1.2%	98.8%	99.7%	-0.9%
38	264	Transmission	2	12,552	Charlton City, MA	0.2%	0.1%	0.3%	99.7%	86.3%	13.4%
39	265E	Transmission	1	7,170	Burrillville, RI	4.7%	0.2%	4.9%	95.1%	91.1%	4.0%
40	266A	Transmission	3	9,170	Mendon, MA	1.6%	3.4%	5.0%	95.0%	98.4%	-3.4%
41	267	Transmission	5	5,000	Hopkinton, MA	8.2%	5.1%	13.3%	86.7%	99.9%	-13.2%
42	270B	Transmission	1	6,053	Concord, NH	41.1%	0.0%	41.1%	58.9%	100.0%	-41.1%
43	303	Transmission	1	16,000	Seneca, PA	1.2%	0.1%	1.3%	98.7%	96.7%	2.0%
44	307	Transmission	6	15,500	Pigeon, PA	4.8%	7.0%	11.8%	88.2%	100.0%	-11.8%
45	310	Transmission	1	16,000	Smethport, PA	0.5%	0.0%	0.5%	99.5%	99.6%	-0.1%
46	313	Transmission	10	24,170	Coudersport, PA	0.7%	1.3%	2.0%	98.0%	81.3%	16.7%
47	313A	Transmission	2	4,730	Ellisburg, PA	99.4%	0.0%	99.4%	0.6%	0.2%	0.4%
48	315	Transmission	2	28,630	Wellsboro, PA	1.3%	0.0%	1.3%	98.7%	99.8%	-1.1%
49	317	Transmission	2	28,900	Troy, PA	0.5%	0.1%	0.6%	99.4%	98.6%	0.8%
50	319	Transmission	1	20,500	Wyalusing, PA	35.8%	0.0%	35.8%	64.2%	100.0%	-35.8%
51	321	Transmission	5	36,317	West Clifford, PA	1.1%	8.7%	9.8%	90.2%	100.0%	-9.8%
52	323A	Transmission	2	27,800	Hawley, PA	0.5%	2.0%	2.5%	97.5%	81.9%	15.6%
53	325	Transmission	3	41,122	Sussex, NJ	1.2%	0.5%	1.7%	98.3%	94.6%	3.7%
54	327	Transmission	1	19,000	West Milford, NJ	1.7%	4.4%	6.1%	93.9%	98.4%	-4.5%
55	405A	Transmission	1	7,700	Avoca, NY	0.4%	0.1%	0.5%	99.5%	96.5%	3.0%

1/ Compressor availability and outages for each compressor station weighted by horsepower at each station.

Reliability Metrics: Compressor Availability

						Current Period	Current Period	Current Period	Current Period	Previous Period	y-o-y variance
						Planned Compressor Outage, % of Total Hours 1/	Unplanned Compressor Outage, % of Total Hours 1/	Compressor Outage, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/	Compressor Availability, % of Total Hours 1/
Line No.	Compressor Station	Compressor Use	# of Units	Horsepower	Location						
56	409	Transmission	3	14,470	Edinburg, TX	3.3%	0.5%	3.8%	96.2%	96.2%	0.0%
57	409A	Transmission	2	4,450	Edinburg, TX	0.2%	0.1%	0.2%	99.8%	100.0%	-0.2%
58	500C-1	Transmission	1	4,498	Natchitoches, LA	2.9%	6.3%	9.3%	90.7%	98.2%	-7.4%
59	504	Transmission	2	6,900	Pitkin, LA	1.1%	0.0%	1.1%	98.9%	89.6%	9.2%
60	523R	Transmission	1	3,594	Lirette, LA	0.0%	0.0%	0.0%	100.0%	0.0%	100.0%
61	527	Transmission	4	42,214	Port Sulfur, LA	0.1%	1.1%	1.3%	98.7%	82.5%	16.3%
62	529	Transmission	1	23,470	Yscloskey, LA	0.0%	4.1%	4.1%	95.9%	0.0%	95.9%
63	530	Transmission	9	25,100	Bay St. Louis, MS	4.8%	5.5%	10.3%	89.7%	18.8%	70.9%
64	534	Transmission	7	26,000	Purvis, MS	18.3%	8.9%	27.2%	72.8%	85.8%	-13.0%
65	538	Transmission	9	27,107	Heidelberg, MS	1.5%	6.8%	8.3%	91.7%	61.5%	30.2%
66	542	Transmission	5	29,500	Dekalb, MS	18.3%	2.4%	20.7%	79.3%	51.0%	28.4%
67	546	Transmission	8	30,000	Columbus, MS	4.8%	20.0%	24.8%	75.2%	68.4%	6.8%
68	550	Transmission	5	29,500	Hamilton, AL	3.0%	13.4%	16.4%	83.6%	80.6%	3.0%
69	555	Transmission	7	25,000	Collinwood, TN	2.1%	9.7%	11.8%	88.2%	87.4%	0.8%
70	563	Transmission	2	60,000	Joelton, TN	6.7%	3.9%	10.5%	89.5%	90.5%	-1.1%
71	703A	Transmission	1	7,700	Mansfield, LA	0.4%	0.0%	0.4%	99.6%	99.8%	-0.2%
72	820	Transmission	2	9,150	Starks, LA	0.0%	1.2%	1.2%	98.8%	50.0%	48.8%
73	823	Transmission	13	32,650	Kinder, LA	10.4%	8.7%	19.1%	80.9%	77.7%	3.2%
74	827	Transmission	1	15,900	Alexandria, LA	0.6%	0.1%	0.7%	99.3%	98.0%	1.3%
75	834	Transmission	7	11,350	Winnsboro, LA	19.0%	1.6%	20.6%	79.4%	74.2%	5.3%
76	836A	Transmission	1	15,900	Delhi, LA	0.8%	0.0%	0.8%	99.2%	99.4%	-0.2%
77	838	Transmission	8	16,350	Lake Providence, LA	0.0%	0.2%	0.2%	99.8%	100.0%	-0.2%
78	843	Transmission	9	14,350	Isola, MS	0.0%	0.0%	0.0%	100.0%	74.9%	25.0%
79	847	Transmission	2	13,400	Coffeetown, MS	0.1%	1.2%	1.3%	98.7%	85.3%	13.4%
80	851	Transmission	8	13,600	New Albany, MS	13.8%	0.6%	14.4%	85.6%	84.9%	0.7%
81	856	Transmission	2	12,500	Savannah, TN	0.0%	0.0%	0.0%	100.0%	100.0%	0.0%
82	860	Transmission	10	31,600	Centerville, TN	1.8%	7.9%	9.7%	90.3%	35.8%	54.6%
83	871	Transmission	3	13,500	Campbellsville, KY	1.3%	17.2%	18.5%	81.5%	64.1%	17.4%
84	871A	Transmission	2	2,400	Dry Creek, KY	0.0%	0.0%	0.0%	100.0%	94.0%	6.0%
85	875	Transmission	1	16,000	Richmond, KY	1.4%	0.0%	1.4%	98.6%	95.7%	2.9%
86	313	Storage	4	5,280	Coudersport, PA	6.8%	1.1%	7.8%	92.2%	80.1%	12.1%

1/ Compressor availability and outages for each compressor station weighted by horsepower at each station.

Reliability Metrics: Firm Service Availability

For the period October 1, 2024 through March 31, 2025

- TGP experienced restrictions in primary-in-path firm service in 1 of its DART segments (out of 110 DART segments)

Pipeline Segment	DART Segment	State	No. Days Total	No. Days w/ Restrictions	No. Days w/ FM Outages	Avg Daily Cut Dth/d	Reduction Reason	% Available During Reporting Period
Zone 0 - 400 Line (MLV 406)	406	TX	182	8	0	122,995	Pipeline Maint (PLM)	97.21%

For the period April 1, 2025 through September 30, 2025

- TGP experienced restrictions in primary-in-path firm service in 4 of its DART segments (out of 110 DART segments)
- 31 days were related to force majeure outages in DART segments 187 and 114

Pipeline Segment	DART Segment	State	No. Days Total	No. Days w/ Restrictions	No. Days w/ FM Outages	Avg Daily Cut Dth/d	Reduction Reason	% Available During Reporting Period
Zone 1 - 500 Line (STA 860 SOUTH 500 LINE)	548	AL	183	25	0	180,164	Pipeline Maint (PLM)	98.19%
Zone 2 - 100 Line (STA 110 SOUTH)	187	KY	183	24	24	107,610	Force Majeure (FMJ)	99.30%
Zone 3 - 100 Line (STA 114 EAST)	114	WV	183	13	7	29,316	PLM/Force Majeure (FMJ)	99.73%
Zone 4 - 200 Line (STA 204)	204	OH	183	57	0	155,786	Pipeline Maint (PLM)	96.35%

Reliability Metrics: Force Majeure Explanations

Event	Pipeline Segment	DART Segment	State	Outage Duration	Date Range	Explanation
Force Majeure	Zone 2 - 100 Line (STA 110 SOUTH)	187	KY	24	7/12 - 8/4	Tennessee discovered anomalies which necessitated immediate repairs.
Force Majeure	Zone 3 - 100 Line (STA 114 EAST)	114	WV	7	8/29 – 9/4	An issue was found at ST 119 Unit 1A during a 4K hour inspection.

