

**TGP - Outage Impact Report  
Seven Day Forecast (updated 11/19/20)**

-Primary impact restrictions may be necessary  
-Major impact restrictions may be necessary  
-Minor impact restrictions may be necessary depending on flow conditions  
-Little to no impact, though minor outages may cause incremental reductions

Station / Seg	Est Nominal Operating Capacity (Thousand Dth)	Monday (11/23)	Tuesday (11/24)	Wednesday (11/25)	Thursday (11/26)	Friday (11/27)	Saturday (11/28)	Sunday (11/29)	Primary Outage(s) that may Impact Throughput
		Est. Operational Capacity (Operational Impact) - Thousand Dth							
Station 409 (Donna Line) (segment 490 FH)	589	589	589	589	589	589	589	589	
Station 1 (segment 101 BH)	313	313	313	313	313	313	313	313	
Station 9 (segment 109 BH)	1,061	1,061	1,061	1,061	1,061	1,061	1,061	1,061	
Station 25 (segment 125 BH)	889	889	889	889	889	889	889	889	
Station 823 (segment 823 BH)	708	708	708	708	708	708	708	708	
Station 834 (segment 834 BH)	723	723	723	723	723	723	723	723	
Station 860 (segment 548 BH)	1,648	1530 (118)	1530 (118)	1530 (118)	1,648	1,648	1,648	1,648	Sta 555: Unit 1B: Automation Upgrade (10/31/2020 - 11/25/2020)
Station 860 North (Segment 860 BH)	1,968	1,968	1,968	1,968	1,968	1,968	1,968	1,968	
Station 110 (segment 187 BH) (south thru Kentucky)	2,754	2685 (69)	2685 (69)	2685 (69)	2685 (69)	2685 (69)	2685 (69)	2685 (69)	MLV 87-2 to MLV 96-2: Anomaly Remediation From ILI (9/14/2020 - 12/30/2020) MLV 96-1 to MLV 106-1: Anomaly Remediation From ILI (10/27/2020 - 12/19/2020) MLV 100-2 to MLV 101-2: Class Change (11/16/2020 - 12/4/2020)
Station 114 (segment 114 BH)	940	940	940	940	940	940	940	940	MLVS 122: Broad Run Cornwell Meter: Emergent Repair (8/8/2017 - 12/31/2021)
Station 204 (Segment 204 BH)	1,906	1,906	1,906	1,906	1,906	1,906	1,906	1,906	
Station 245 (segment 245 FH)	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	
Station 261 Discharge (segment 261 FH)	995	995	995	995	995	995	995	995	
Station 307 (segment 307 BH)	1,204	1,204	1,204	1,204	1,204	1,204	1,204	1,204	
Station 315 (segment 315 BH)	1,977	1,977	1,977	1,977	1,977	1,977	1,977	1,977	
Station 325 (segment 324 FH)	1,721	1,721	1,721	1,721	1,721	1,721	1,721	1,721	
Station 405 HC Line (segment 299 FH)	824	824	824	824	824	824	824	824	

This document is updated on a weekly basis and outage schedules/impacts are subject to change as the week progresses.  
Dates posted on DART should be deemed correct in the event of conflicts between DART posted dates and dates on this report.  
The impacts sheet are based on steady-state hydraulic models assuming recent operating flows, conditions, and various unit outages.

**TGP - Outage Impact Report  
Seven Day Forecast (updated 11/19/20)**

-Primary impact restrictions may be necessary

-Major impact restrictions may be necessary

-Minor impact restrictions may be necessary depending on flow conditions

-Little to no impact, though minor outages may cause incremental reductions

Station / Seg	Est Nominal Operating Capacity (Thousand Dth)	Monday (11/30)	Tuesday (12/1)	Wednesday (12/2)	Thursday (12/3)	Friday (12/4)	Saturday (12/5)	Sunday (12/6)	Primary Outage(s) that may Impact Throughput
		Est. Operational Capacity (Operational Impact) - Thousand Dth							
Station 409 (Donna Line) (segment 490 FH)	589	589	589	589	589	589	589	589	
Station 1 (segment 101 BH)	313	313	313	313	313	313	313	313	
Station 9 (segment 109 BH)	1,061	1,061	1,061	1,061	1,061	1,061	1,061	1,061	
Station 25 (segment 125 BH)	889	889	889	889	889	889	889	889	
Station 32 (segment 132 BH)	889	850 (39)	850 (39)	850 (39)	850 (39)	850 (39)	850 (39)	850 (39)	MLV 36-3 to MLV 36-3A: Emergent Hydrostatic Pressure Test (11/30/2020 - 12/19/2020)
Station 823 (segment 823 BH)	708	708	708	708	708	708	708	708	
Station 834 (segment 834 BH)	723	723	723	723	723	723	723	723	
Station 860 (segment 548 BH)	1,648	1,648	1,648	1,648	1,648	1,648	1,648	1,648	
Station 860 North (Segment 860 BH)	1,968	1,968	1,968	1,968	1,968	1,968	1,968	1,968	
Station 110 (segment 187 BH) (south thru Kentucky)	2,754	2650 (104)	2650 (104)	2650 (104)	2650 (104)	2295 (459)	2295 (459)	2295 (459)	MLV 87-2 to MLV 96-2: Anomaly Remediation From ILI (9/14/2020 - 12/30/2020) MLV 96-1 to MLV 106-1: Anomaly Remediation From ILI (10/27/2020 - 12/19/2020) MLV 100-2 to MLV 101-2: Class Change (11/16/2020 - 12/4/2020) Sta 110: Units 6A, 8A, & 9A: Electrical Inspections (11/30/2020 - 12/4/2020) Sta 87: Unit 3D: Exhaust Bolts (11/30/2020 - 12/11/2020) Sta 106: Station Yard Valves Tie In (12/4/2020 - 12/13/2020)
Station 114 (segment 114 BH)	940	940	820 (120)	820 (120)	940	940	940	940	MLVS 122: Broad Run Cornwell Meter: Emergent Repair (8/8/2017 - 12/31/2021) Sta 119: Unit 1A: 4k Inspection (12/1/2020 - 12/2/2020)
Station 204 (Segment 204 BH)	1,906	1845 (61)	1845 (61)	1845 (61)	1845 (61)	1845 (61)	1845 (61)	1845 (61)	Sta 209: Unit 10A: Catwalk Replacement (11/30/2020 - 12/10/2020) Sta 204: Unit 1A: Oil Filter Replacement (11/30/2020 - 12/18/2020)
Station 245 (segment 245 FH)	1,064	1,064	1,064	1,064	1,064	1,064	1,064	1,064	
Station 261 Discharge (segment 261 FH)	995	995	995	995	995	995	995	995	
Station 307 (segment 307 BH)	1,204	1,204	1,204	1,204	1,204	1,204	1,204	1,204	
Station 315 (segment 315 BH)	1,977	1,977	1,977	1,977	1,977	1,977	1,977	1,977	
Station 325 (segment 324 FH)	1,721	1,721	1,721	1,721	1,721	1,721	1,721	1,721	
Station 405 HC Line (segment 299 FH)	824	824	824	824	824	824	824	824	

This document is updated on a weekly basis and outage schedules/impacts are subject to change as the week progresses.  
Dates posted on DART should be deemed correct in the event of conflicts between DART posted dates and dates on this report.  
The impacts sheet are based on steady-state hydraulic models assuming recent operating flows, conditions, and various unit outages.

**TGP - Outage Impact Report  
December 2020 (updated 11/19/20)**

-Primary impact restrictions may be necessary

-Major impact restrictions may be necessary

-Minor impact restrictions may be necessary depending on flow conditions

-Little to no impact, though minor outages may cause incremental reductions

Station # / Lateral	Est Nominal Operating Capacity (Thousand Dth)	Week 1	Week 2	Week 3	Week 4	Week 5	Primary Outage(s)
		(11/30 - 12/6)	(12/7 - 12/13)	(12/14 - 12/20)	(12/21 - 12/27)	(12/28 - 1/3)	
Est. Operational Capacity (Operational Impact) - Thousand Dth							
Station 409 (Donna Line) (segment 490 FH)	589		589	589	589	589	
Station 1 (segment 101 BH)	313		313	313	313	313	
Station 9 (segment 109 BH)	1,061		1040 (21)	1040 (21)	1,061	1,061	MLV 5-2 to MLV 2-2: Pipe Replacement (12/7/2020 - 12/18/2020)
Station 25 (segment 125 BH)	889		880 (9)	889	889	880 (9)	Sta. 25: Annual ESD test (12/7/2020 - 12/11/2020) Sta. 25: Annual Electrical Inspection (12/7/2020 - 12/11/2020) Sta 25: Unit 1C: Electrical Test & Borescope (12/31/2020)
Station 32 (segment 132 BH)	889		850 (39)	850 (39)	889	889	MLV 36-3 to MLV 36-3A: Emergent Hydrostatic Pressure Test (11/30/2020 - 12/19/2020)
Station 823 (segment 823 BH)	708		708	708	708	708	
Station 834 (segment 834 BH)	723		723	723	723	723	
Station 860 (segment 548 BH)	1,648		1,648	1,648	1,648	1,648	
Station 860 North (Segment 860 BH)	1,968		1,968	1360 (608)	1,968	1,968	Sta 563: Protective Device Checks & Engine Inspections (12/14/2020 - 12/18/2020)
Station 110 (segment 187 BH) (south thru Kentucky)	2,754		2295 (459)	2710 (44)	2710 (44)	2710 (44)	MLV 87-2 to MLV 96-2: Anomaly Remediation From ILI (9/14/2020 - 12/30/2020) MLV 96-1 to MLV 106-1: Anomaly Remediation From ILI (10/27/2020 - 12/19/2020) Sta 87: Unit 3D: Exhaust Bolts (11/30/2020 - 12/11/2020) Sta 106: Station Yard Valves Tie In (12/4/2020 - 12/13/2020)
Station 114 (segment 114 BH)	940		940	846 (94)	940	940	MLVS 122: Broad Run Cornwell Meter: Emergent Repair (8/8/2017 - 12/31/2021) Sta 114: Unit 1D: 4k Inspection (12/14/2020 - 12/15/2020)
Station 204 (Segment 204 BH)	1,906		1845 (61)	1845 (61)	1855 (51)	1,906	Sta 209: Unit 10A: Catwalk Replacement (11/30/2020 - 12/10/2020) Sta 204: Unit 1A: Oil Filter Replacement (11/30/2020 - 12/18/2020) Sta 209: Unit 9A: Catwalk Replacement (12/14/2020 - 12/24/2020)
Station 245 (segment 245 FH)	1,064		1,064	1,064	1,064	1,064	
Station 261 Discharge (segment 261 FH)	995		995	995	995	995	
Station 307 (segment 307 BH)	1,204		1125 (79)	1,204	1,204	1,204	Sta 307: Unit 2A: DOT & Non-DOT protective device testing, pocket control upgrade project (12/7/2020 - 12/11/2020)
Station 315 (segment 315 BH)	1,977		1,977	1,977	1,977	1,977	
Station 325 (segment 324 FH)	1,721		1,721	1,721	1,721	1,721	
Station 405 HC Line (segment 299 FH)	824		824	824	824	824	

This document is updated on a weekly basis and outage schedules/impacts are subject to change as the week progresses.  
Dates posted on DART should be deemed correct in the event of conflicts between DART posted dates and dates on this report.  
The impacts sheet are based on steady-state hydraulic models assuming recent operating flows, conditions, and various unit outages.

**TGP - Outage Impact Report  
January 2021 (updated 11/19/20)**

-Primary impact restrictions may be necessary

-Major impact restrictions may be necessary

-Minor impact restrictions may be necessary depending on flow conditions

-Little to no impact, though minor outages may cause incremental reductions

Station # / Lateral	Est Nominal Operating Capacity (Thousand Dth)	Week 1 (1/4 - 1/10)	Week 2 (1/11 - 1/17)	Week 3 (1/18 - 1/24)	Week 4 (1/25 - 1/31)	Primary Outage(s)
		Est. Operational Capacity (Operational Impact) - Thousand Dth				
Station 409 (Donna Line) (segment 490 FH)	589	589	589	589	589	
Station 1 (segment 101 BH)	313	313	313	313	313	
Station 9 (segment 109 BH)	1,061	1,061	1,061	1,061	1,061	
Station 25 (segment 125 BH)	889	889	889	889	889	
Station 32 (segment 132 BH)	889	889	870 (19)	889	889	MLV 40-2 to MLV 32-2: Maintenance Pig (M) (1/12/2021)
Station 823 (segment 823 BH)	708	708	708	708	708	
Station 834 (segment 834 BH)	723	723	723	723	723	
Station 860 (segment 548 BH)	1,648	1,648	1,648	1,648	1,648	
Station 860 North (Segment 860 BH)	1,968	1,968	1,968	1,968	1,968	
Station 110 (segment 187 BH) (south thru Kentucky)	2,754	2,754	2,754	2,754	2,754	
Station 114 (segment 114 BH)	940	940	940	940	940	MLVS 122: Broad Run Cornwell Meter: Emergent Repair (8/8/2017 - 12/31/2021)
Station 204 (Segment 204 BH)	1,906	1840 (66)	1895 (11)	1,906	1,906	Sta 204: Unit 12A: Air Cleaner Base Replacement (1/5/2021 - 1/6/2021) Sta 200: Unit 3A: 10k Inspection (1/11/2021 - 1/15/2021)
Station 245 (segment 245 FH)	1,064	1,064	1,064	1,064	1,064	
Station 261 Discharge (segment 261 FH)	995	995	995	995	995	
Station 307 (segment 307 BH)	1,204	1,204	1,204	1,204	1,204	
Station 315 (segment 315 BH)	1,977	1,977	1,977	1,977	1,977	
Station 325 (segment 324 FH)	1,721	1,721	1,721	1,721	1,721	
Station 405 HC Line (segment 299 FH)	824	824	824	824	824	

This document is updated on a weekly basis and outage schedules/impacts are subject to change as the week progresses.  
Dates posted on DART should be deemed correct in the event of conflicts between DART posted dates and dates on this report.  
The impacts sheet are based on steady-state hydraulic models assuming recent operating flows, conditions, and various unit outages.

**TGP - Outage Impact Report  
February 2021 (updated 11/19/20)**

-Primary impact restrictions may be necessary

-Major impact restrictions may be necessary

-Minor impact restrictions may be necessary depending on flow conditions

-Little to no impact, though minor outages may cause incremental reductions

Station # / Lateral	Est Nominal Operating Capacity (Thousand Dth)	Week 1 (2/1 - 2/7)	Week 2 (2/8 - 2/14)	Week 3 (2/15 - 2/21)	Week 4 (2/22 - 2/28)	Primary Outage(s)
		Est. Operational Capacity (Operational Impact) - Thousand Dth				
Station 409 (Donna Line) (segment 490 FH)	589	589	589	589	589	
Station 1 (segment 101 BH)	313	313	313	313	313	
Station 9 (segment 109 BH)	1,061	1,061	1,061	1,061	1,061	
Station 25 (segment 125 BH)	889	889	889	889	889	
Station 823 (segment 823 BH)	708	708	708	708	708	
Station 834 (segment 834 BH)	723	723	723	723	723	
Station 847 (segment 847 BH)	318	318	215 (103)	318	318	MLV 851-1 to MLV 856-1: Pig Run - Cleaning / Gauge 2/8/21, Caliper 2/9/21, MFL 2/11/21 (M) (2/8/2021 - 2/11/2021)
Station 860 (segment 548 BH)	1,648	1,648	1,648	1,648	1,648	
Station 860 North (Segment 860 BH)	1,968	1,968	1,968	1,968	1,968	
Station 110 (segment 187 BH) (south thru Kentucky)	2,754	2,754	2,754	2,754	2,754	
Station 114 (segment 114 BH)	940	940	940	940	940	MLVS 122: Broad Run Cornwell Meter: Emergent Repair (8/8/2017 - 12/31/2021)
Station 204 (Segment 204 BH)	1,906	1,906	1,906	1,906	1,906	
Station 245 (segment 245 FH)	1,064	1,064	1,064	1,064	1,064	
Station 261 Discharge (segment 261 FH)	995	995	995	995	995	
Station 307 (segment 307 BH)	1,204	1,204	1,204	1125 (79)	1125 (79)	Sta 307: Unit 3A: Foundation Replacement (2/15/2021 - 5/21/2021)
Station 315 (segment 315 BH)	1,977	1,977	1,977	1,977	1,977	
Station 325 (segment 324 FH)	1,721	1,721	1,721	1,721	1,721	
Station 405 HC Line (segment 299 FH)	824	824	824	824	824	

This document is updated on a weekly basis and outage schedules/impacts are subject to change as the week progresses.  
Dates posted on DART should be deemed correct in the event of conflicts between DART posted dates and dates on this report.  
The impacts sheet are based on steady-state hydraulic models assuming recent operating flows, conditions, and various unit outages.