

WIC Planned Outage	Start Date	Finish Date	State	Maintenance Activity
X16-373036	6/1/2016	12/31/2018	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station the GE unit 4 is out of service repair pending .Capacity will be limited to 1075 Mdthd until further notice.
X18-1442	1/23/2019	1/24/2019	Wyoming	THREEMILE LATERAL TO REX (Segment 420): Wamsutter Jumper, WIC will perform unit maintenance January 23 through January 24 .Capacity will be reduced to zero
X18-998626	2/6/2019	2/7/2019	Wyoming	PICENANCE LATERAL - COLORADO (Segment 422): Piceance Station one unit be out of service February 6 through February 7 to perform mechanical inspection. Capacity will be reduced to 456 Mdth/d.
X17-10225	2/26/2019	2/26/2019	Wyoming	WIC Echo Springs (Segment 428): Creston Compressor Station On February 26 unit will be down for mechanical maintenance. Capacity will be reduced to 67Mdthd
X19-28493	3/5/2019	3/5/2019	Colorado	PICEANCE LATERAL - COLORADO (Segment 422): Snake River Compressor Station .One unit will be out of service for inspection March 5. Capacity will be reduced to 491 Mdth/d.
X19-28491	3/6/2019	3/7/2019	Colorado	PICENANCE LATERAL - COLORADO (Segment 422): Piceance Station one unit be out of service March 6 through March 7 to perform mechanical inspection. Capacity will be reduced to 456 Mdth/d.
X18-1430	3/26/2019	3/26/2019	Colorado	PICENANCE LATERAL - COLORADO (Segment 422): Piceance Station will be out of service March 26 through March 28 to perform ESD tests and unit shutdown checks. Capacity will be reduced to 456 Mdth/d.
X18-1275	4/11/2019	4/11/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service April 11 for mechanical inspection. No impact is anticipated.
X18-1276	4/12/2019	4/12/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service April 12 for mechanical inspection. No impact is anticipated.
X18-1450	4/23/2019	4/24/2019	Wyoming	THREEMILE LATERAL TO REX (Segment 420): Wamsutter Jumper, WIC will perform ESD test and unit shutdown checks April 23 . Capacity will be reduced to zero
X18-1444	5/8/2019	5/8/2019	Wyoming	WIC Echo Springs (Segment 428): Creston Compressor Station On May 8 unit will be down for mechanical maintenance. Capacity will be reduced to 67 Mdthd
X18-1284	5/15/2019	5/15/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station The station will be out of service May 15 for 12 hours for Annual DOT Checks. Capacity will be reduced to 325 Mdth/d.
X18-1287	5/21/2019	5/21/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service May 21 unit shutdown checks . No impact is anticipated.
X18-1291	5/22/2019	5/22/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service May 22 unit shutdown checks .
X18-1293	5/23/2019	5/23/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service May 23 unit shutdown checks .

X18-1433	5/28/2019	5/28/2019	Wyoming	PICEANCE LATERAL - CO (Segment 422):Snake River Compressor Station Annual DOT ESD tests will be performed May 28. Capacity will be reduced to 406 Mdth/d.
X18-1295	6/3/2019	6/3/2019	Wyoming	WIC/CIG(FLY) FLYING HAWK WELD (800245) - WIC Cheyenne Station June 3 one unit will be out of service to perform unit shut down checks . Capacity at the Flying Hawk WIC to CIG Meter Station 800245 will be reduced to 850 Mdth/d.
X18-1296	6/4/2019	6/4/2019	Wyoming	WIC/CIG(FLY) FLYING HAWK WELD (800245) - WIC Cheyenne Station June 4 one unit will be out of service to perform unit shut down checks . Capacity at the Flying Hawk WIC to CIG Meter Station 800245 will be reduced to 850 Mdth/d.
X18-1297	6/5/2019	6/5/2019	Wyoming	WIC/CIG(FLY) FLYING HAWK WELD (800245) - WIC Cheyenne Station June 5 one unit will be out of service to perform unit shut down checks . Capacity at the Flying Hawk WIC to CIG Meter Station 800245 will be reduced to 850 Mdth/d.
X18-1298	6/6/2019	6/6/2019	Wyoming	WIC/CIG(FLY) FLYING HAWK WELD (800245) - WIC Cheyenne Station June 6 one unit will be out of service to perform unit shut down checks . Capacity at the Flying Hawk WIC to CIG Meter Station 800245 will be reduced to 850 Mdth/d.
X18-783431	6/19/2019	6/20/2019	Wyoming	WIC Wyoming Mainline (SEGMENT W11): 124A-36" On June 19 through June 20 WIC will perform ILI pigging operations Wamsutter to Kanda . Capacity will be reduced to 325 Mdthd.
X18-1304	7/11/2019	7/11/2019	Wyoming	WIC/CIG(FLY) FLYING HAWK WELD (800245): Cheyenne WIC Compressor Station Annual DOT ESD systems checks will be performed on July 11 for 12 hours. Capacity at the Flying Hawk WIC to CIG Meter Station 800245 will be reduced to 663 Mdth/d.
X18-1443	7/11/2019	7/11/2019	Wyoming	THREEMILE LATERAL TO REX (Segment 420): Wamsutter Jumper, WIC will perform unit maintenance July 11 .Capacity will be reduced to zero
X18-783432	7/23/2019	7/24/2019	Wyoming	WIC Wyoming Mainline (SEGMENT W11): 124A-36" On July 23 through July 24 WIC will perform ILI pigging operations Wamsutter to Kanda. Capacity will be reduced to 325 Mdthd.
X18-1455	7/23/2019	7/23/2019	Wyoming	WIC Echo Springs (Segment 428): Creston Compressor Station On July 23 unit will be down for mechanical maintenance. Capacity will be reduced to 67Mdthd
X18-783433	7/25/2019	7/26/2019	Wyoming	WIC Wyoming Mainline (SEGMENT W11): 124A-36" On July 25 through July 26 WIC will perform ILI pigging operations Wamsutter to Kanda. Capacity will be reduced to 325 Mdthd.
X18-1309	8/13/2019	8/13/2019	Wyoming	MEDICINE BOW - WYOMING (Segment 440): Douglas Compressor Station one unit will be out of service August 13 for mechanical inspection. No impact is anticipated.
X18-1461	8/13/2019	8/14/2019	Wyoming	WIC Echo Springs (Segment 428):Creston Compressor Station will be out of service August 13 through August 14 to perform Annual DOT ESD systems checks. Capacity will be reduced to zero.

X18-1435	8/20/2019	8/20/2019	Wyoming	KANDA LATERAL - COLORADO NORTH (Segment 404): Diamond Mountain Compressor Station will be out of service August 20 to perform annual DOT ESD test. Capacity will be reduced to 380 Mdth/d.
X18-1462	10/15/2019	10/15/2019	Wyoming	WIC Echo Springs (Segment 428): Creston Compressor Station On October 15 unit will be down for mechanical maintenance. Capacity will be reduced to 67Mdthd
X18-936950	12/31/2019	12/31/2019	Wyoming	WIC Echo Springs (Segment 428): Creston Compressor Station On December 31 unit will be down for mechanical maintenance. Capacity will be reduced to 67Mdthd